NC/QC/YD-W04/2020-21/DB-W1

Date: 15-06-2020

TEST REPORT ON WET MIX MACADAM MIX

(GRADATION TEST)

Sub: To conduct Gradation test on Wet Mix Macadam (WMM) Mix.
{Project*: Drilling of Borewell , And other Civil works at Slum Area in ward no.4.}
Ref.: Material testing/QC/20-21,
Report Required for: Assistant Executive Engineer,
Yelahanka New Town Sub Division,
BBMP, Bangalore.
Name of the Agency/Contractor*: M/s KRIDL.

TEST RESULTS

1. Gradation Test:

TABLE 1.1

Sieve Size mm	Percent by Weight passing the Sieve from the sample supplied (Obtained Gradation)	Specified Limits as per MoRTH Specifications, V Revision-2013
53.00	100.00	100
45.00	96.15	95-100
26.50	---	-
22.40	70.40	60-80
11.20	54.70	40-60
4.75	29.35	25-40
2.36	22.85	15-30
0.600	13.55	8-22
0.075	3.60	0-5

NEWZEN CONSULTANT BANGALORE

NEWZEN CONSULTANT BANGALORE, #13,10TH MAIN ROAD 2ND CROSS JNANAJYOTHI NAGARA,
JNANABHARATHI, BANGALORE-560056. CELL NO: +91 8792620231, 080 23240187
EMAIL:newzen576@gmail.com